

MINIMAX

MOBILE SERVICES



MOBILE POWDER EXTINGUISHING SYSTEM IN A CONTAINER ON WHEELS

P 250 RC (ABC) and P 250 RC (ABC) Light

PRODUCT

- ▶ Fire extinguishing systems using ABC extinguishing powder are ideal for suppressing initial fires of fire classes A, B, and C.
- ▶ The extinguishing effect in fire class B is based on the anticatalytic effect, where the powder particles intervene in the combustion process and thus extinguish the fire. In the case of burning materials forming embers (fire class A), the extinguishing powder produces an additional blocking effect by forming a molten layer, which prevents the inflow of oxygen. In addition, it prevents the reignition of a fire.

APPLICATION


- ▶ Extinguishing powder is used in all cases, where flammable material of a wide variety is to be expected. It reliably extinguishes burning solid materials of an organic nature, liquids or liquefiable solids and gases.
- ▶ Typical areas of application are:
 - Chemical and petrochemical industry
 - Metal casting works
 - Galvanizing operations
 - Supply and disposal utilities
 - Energy suppliers
 - Corporate and municipal fire brigades

YOUR ADVANTAGES


- ▶ Substantial stock of extinguishing agent
- ▶ Long shelf life of the extinguishing agent
- ▶ Excellent extinguishing effect due to a three-dimensional powder cloud
- ▶ The extinguishing agent jet is adjustable at all times, meaning flow control is easy
- ▶ High level of operational safety
- ▶ Maintenance-friendly
- ▶ Easy operation
- ▶ Flexible transportability
- ▶ Safe to use thanks to a deadman brake
- ▶ High-quality materials
- ▶ Harmless for people, animals and the environment




FUNCTION




1. Open test valve.




2. Rotate cylinder valve anticlockwise.



3. Roll out the hose, making sure it is free of kinks.



4. After reaching approx. 8 bar container pressure, open the applicator shut-off valve.



5. Aim the applicator at the fire and press the trigger.

- ▶ When opening the cylinder valve, propellant gas flows through the connecting line and through the gas injection into the extinguishing agent container. This causes the extinguishing power to swirl around. After pressing the shut-off valve at the powder outlet, the powder is propelled into the extinguishing hose and is ejected as a powder cloud when activating the extinguishing pistol. The flow of the extinguishing powder stops when the lever is released. By alternately pressing and releasing the applicator lever, fires that have formed glowing embers can be extinguished through short bursts of extinguishing powder. When extinguishing liquid or gas fires, do not interrupt the powder jet!
- ▶ Close the cylinder valve after ending the use of the fire extinguisher. Rinse the hose and reduce the container pressure opening the rinse valve. The device must be refilled, operational readiness must be reinstated without undue delay and the empty nitrogen cylinder must be replaced by a full one.

TECHNICAL DATA

Model	Extinguishing agent capacity	Extinguishing agent	Propellant gas	Test pressure	Operating pressure (max. PS) at +60 °C approx. bar	Discharge range approx. m	Temperature function range °C	Performance classes	Width approx. mm	Height approx. mm	Length approx. mm	Weight approx. kg
P 250 RC (ABC), P 250 RC (ABC) Light	250 kg	ABC extinguishing powder	Nitrogen	20,2 bar	13 approx. bar	8 - 10	-20 to +60		800	1200	1200	570
Technical alterations reserved												
Model	Chassis	Forklift pockets	Extinguishing agent container*	Propellant gas container	Release	Extinguishing control device	Safety components					
P 250 RC (ABC)	Container on wheels, 4 casters with directional locks, with deadman brake	yes	Filling nozzle in upper section	Nitrogen cylinder**, content 25 l, filling pressure 200 bar	Manual system activation using the rotary valve	30 m foldable flat hose C32 with powder applicator	Safety valve					
P 250 RC (ABC) Light	Container on wheels, 2 fixed casters + 2 casters with directional locks, with deadman brake	no	Filling nozzle in upper section	Nitrogen cylinder**, content 25 l, filling pressure 200 bar	Manual system activation using the rotary valve	20 m foldable flat hose C32 with powder applicator	Safety valve					
* Pressure container, approved according to Pressure Equipment Directive 2014/68/EU ** approved according to the Directive on transportable pressure equipment 2010/35/EU												



MAINTENANCE

- ▶ Extinguishing systems must be regularly maintained by certified experts.
- ▶ All maintenance and filling tasks are to be carried out by your Minimax Service.

Follow Minimax Mobile Services on [LinkedIn](#), [Instagram](#), [Facebook](#) and [YouTube](#).



Minimax Mobile Services GmbH
 Export Department
 Minimaxstraße 1
 D-72574 Bad Urach
 Tel.: +49 (0)7125 154-216
 Fax: +49 (0)7125 154-166
 E-Mail: exportmobile@minimax.de
www.minimax-mobile.co

